


BACKWATER VALVE ASSEMBLY

NTS

NOTES:

1. BACKWATER VALVE SHALL BE LOCATED AS CLOSE AS POSSIBLE TO THE PROPERTY LINE TO ALLOW FOR THE MOST STORAGE.
2. 3" AND 4" CHECK USES A 6" SLEEVE AND 6" USES AN 8" SLEEVE.
3. THE ACCESS SLEEVE MUST TERMINATE ABOVE GRADE AND MUST HAVE A MAXIMUM LENGTH OF 12 FEET.
4. BACKWATER VALVES MAY ONLY BE INSTALLED ON HORIZONTAL DRAINAGE.
5. THE BACKWATER VALVE MUST BE ACCESSIBLE FOR SERVICE AND REPAIRS. THIS INCLUDES THE VERTICAL CLEARANCE NEEDED TO REMOVE THE INTEGRAL LIFTING DEVICE.
6. IF INSTALLED IN TRAFFIC AREA A VAULT WITH A TRAFFIC RATED LID SHALL BE REQUIRED.
7. DO NOT REMOVE CAP WITHOUT CONTACTING C.O.B. FIRST OR DISCHARGE OF SEWER IS POSSIBLE.

	<p>City of Bremerton</p> <hr style="width: 50%; margin: auto;"/> <p>PUBLIC WORKS</p>	<p>GRAVITY SIDE SEWER BACKWATER VALVE ASSEMBLY 4" TO 6" DIAMETER VAULT/MANHOLE NOT REQUIRED</p> <p style="font-size: small;">Alteration of this drawing is prohibited. Any approval of an altered drawing is unauthorized and void.</p>	<p>6072</p> <p style="font-size: small;">Revision Date 11/28/12</p>
<p>DESIGN/CONSTRUCTION STANDARDS</p>			