


TRACER WIRE INSULATED 12 GAUGE GREEN WIRE (SOLID CORE) TO BE WRAPPED AROUND THE PIPE AND LOOPED THRU VALVE BOX FROM COLLECTOR VALVE TO GRINDER CLEANOUT (AS SHOWN).

LOW PRESSURE CLEANOUT DETAIL (FOR NON-TRAFFIC AREAS ONLY)

- ① POLYETHYLENE PRESSURE PIPE SDR 11 (LENGTH TO SUIT)
- ② UNION BALL VALVE PVC (IPxIP)
- ③ FTP x SLIP ADAPTER WITH PLUG
- ④ 90° LONG SWEEP PVC ELL (IPxIP)
- ⑤ NIPPLE PVC (IPxIP) (LENGTH TO SUIT)
- ⑥ PRECAST SOLID BLOCKS
- ⑦ MPT 316 SS IPxHDPE BUTT FUSION TRANSITION FITTING

	<p>City of Bremerton</p> <hr style="width: 20%; margin: auto;"/> <p>PUBLIC WORKS</p> <hr style="width: 20%; margin: auto;"/> <p>DESIGN/CONSTRUCTION STANDARDS</p>	<p>LOW PRESSURE CLEAN-OUT END OF MAIN < 4"</p> <p style="font-size: small;">Alteration of this drawing is prohibited. Any approval of an altered drawing is unauthorized and void.</p>	<p>6122</p> <p style="font-size: x-small;">Revision Date 2/23/15</p>
--	--	--	---