


BACKWATER VALVE ASSEMBLY

NTS

NOTES:

1. 48" MANHOLE CITY "STANDARD MANHOLE" SEE DETAIL 6001.
2. A TRAFFIC RATED LID WILL BE REQUIRED IN DRIVING AREAS.
3. BACKWATER VALVE SHALL BE LOCATED AS CLOSE AS POSSIBLE TO THE PROPERTY LINE TO ALLOW FOR THE MOST STORAGE.
4. DO NOT REMOVE CAP WITHOUT CONTACTING C.O.B. FIRST OR DISCHARGE OF SEWER IS POSSIBLE.

	<p>City of Bremerton</p> <hr style="width: 20%; margin: auto;"/> <p>PUBLIC WORKS</p>	<p>GRAVITY SIDE SEWER BACKWATER VALVE ASSEMBLY 4" TO 6" DIAMETER DEPTH GREATER THAN 3'-0"</p> <p style="font-size: small;">Alteration of this drawing is prohibited. Any approval of an altered drawing is unauthorized and void.</p>	<p>6071</p> <p style="font-size: small;">Revision Date 9/30/14</p>
<p>DESIGN/CONSTRUCTION STANDARDS</p>			