



NOTES:

1. ANY NEW OR EXISTING SEWER MAIN OR LATERAL LOCATED BENEATH A RETAINING WALL OR ROCKERY SHALL BE ENCASED IN A SCHEDULE 40 STEEL, C-900 PVC, OR CLASS 52 D.I. SLEEVE.
2. SPLIT CASINGS ARE ACCEPTABLE.



City of Bremerton

PUBLIC WORKS

DESIGN/CONSTRUCTION STANDARDS

ENCASEMENT

Alteration of this drawing is prohibited. Any approval of an altered drawing is unauthorized and void.

6062

Revision Date
09/24/14