


## BACKWATER VALVE ASSEMBLY

NTS

**NOTES:**

1. A TRAFFIC RATED LID WILL BE REQUIRED IN DRIVING AREAS.
2. BACKWATER VALVE SHALL BE LOCATED AS CLOSE AS POSSIBLE TO THE PROPERTY LINE TO ALLOW FOR THE MOST POSSIBLE STORAGE
3. A MINIMUM OF 24" DIAMETER RISE FOR ACCESS TO ALLOW MAINTENANCE OF DEVICE.
4. DO NOT REMOVE CAP WITHOUT CONTACTING C.O.B. FIRST OR DISCHARGE OF SEWER IS POSSIBLE.

	<p><b>City of Bremerton</b></p> <hr style="width: 50%; margin: auto;"/> <p><b>PUBLIC WORKS</b></p>	<p><b>GRAVITY SIDE SEWER BACKWATER VALVE ASSEMBLY 4" TO 6" DIAMETER MAXIMUM DEPTH 3'-0"</b></p>	<p><b>6070</b></p>
<p><b>DESIGN/CONSTRUCTION STANDARDS</b></p>		<p>Alteration of this drawing is prohibited. Any approval of an altered drawing is unauthorized and void.</p>	<p>Revision Date 9/30/14</p>