


1. THE CLEANOUT MUST BE LOCATED ABOVE HYDRAULIC GRADIENT OF SEWER FORCE MAIN.
2. THE CLEANOUT SHOULD BE LOCATED TO PROVIDE EASY ACCESS FOR INSPECTION AND MAINTENANCE.
3. HDPE METER BOX, MID-STATES #111812 OR RAVEN METER BOX #1118X12 OR APPROVED EQUAL.

	<p>City of Bremerton</p> <hr style="width: 20%; margin: 0 auto;"/> <p>PUBLIC WORKS</p> <hr style="width: 20%; margin: 0 auto;"/> <p>DESIGN/CONSTRUCTION STANDARDS</p>	<p><u>CLEANOUT FOR SEWER</u> <u>FORCE MAINS</u></p> <p style="font-size: small;">Alteration of this drawing is prohibited. Any approval of an altered drawing is unauthorized and void.</p>	<p>6022</p> <p style="font-size: small;">Revision Date 9/18/14</p>
--	--	---	---