


**NOTES:**

1. UTILITY VAULT COMPANY, INC., #577-SA, OR EQUAL
2. LOCATE WITHIN 20 FEET OF DRIVE FOR ACCESS BY MAINTENANCE VEHICLE.
3. INSPECTION AND SAMPLING TEE TO BE INSTALLED BY CONTRACTOR. LINE-SIZED P.V.C. PIPE SHALL BE USED.
4. FILL WITH CLEAN WATER PRIOR TO START-UP OF SYSTEM.
5. GRAY AND BLACK WATER SHALL BE CARRIED BY SEPARATE SIDE SEWER.
6. SIZE WILL BE DETERMINED BY THE VOLUME TREATED.
7. VAULT SIZE TO BE DETERMINED BY SITE SPECIFIC CHARACTERISTICS.

 <b>City of Bremerton</b> <hr style="width: 50%; margin: 0 auto;"/> <b>PUBLIC WORKS</b>	<b>DESIGN/CONSTRUCTION STANDARDS</b>	<b>BAFFLE TYPE</b> <b>OIL/WATER SEPARATOR</b>	<b>4068</b>
			<small>Alteration of this drawing is prohibited. Any approval of an altered drawing is unauthorized and void.</small>