


HORIZONTAL METER INSTALLATION

- (A) CAST IRON SERVICE SADDLE FOR A.C. PVC, & STEEL MAINS, WITH STAINLESS STEEL BANDS. DIRECT TAP AND INSTALL CC CORP. ON D.I. AND C.I. MAINS
- (B) 1" CORPORATION STOP (CC OR IP) X COMPRESSION.
- (C) 1" COPPER TUBING SIZE HIMOL WITH S.S. INTERNAL POLY STIFFENERS, W/ 12 GA. SOLID COPPER BLUE COATED LOCATE WIRE.
- (D) 1" X 3/4" ANGLE METER VALVE, COMPRESSION
- (E) 3/4" ANGLE METER CHECK VALVE IP, OR COMPRESSION.
- (F) HDPE METER BOX WITH EJIW #1118 METER COVER WITH RECESSED TOUCH READ PIT LID ADAPTER HOLE. MID STATES #111812 BOX OR RAVEN METER BOX #1118X12 OR APPROVED EQUAL.

NOTES:

1. SERVICE LINES SHALL BE PERPENDICULAR TO THE WATERMAIN. METER SETTER MAY BE USED WHERE REQUIRED.
2. SERVICE SADDLE MAY BE INSTALLED AS AN OPTION ON CLASS 52 OR THICKER D.I. PIPE. ALL CONNECTIONS WILL BE TAPPED INTO AN "EXISTING WATER MAIN" BY CITY FORCES ONLY.
3. AN APPROVED BACKFLOW ASSEMBLY MUST BE INSTALLED PER WA. DEPT OF HEALTH ON ALL IRRIGATION SYSTEMS. THE SYSTEM SHALL NOT BE PLACED INTO SERVICE UNTIL THE REQUIRED BACKFLOW ASSEMBLY IS INSTALLED (PER CITY STANDARD DETAILS), TESTED BY A CERTIFIED BACKFLOW ASSY. TESTER, AND INSPECTED BY A CERTIFIED CROSS CONNECTION CONTROL SPECIALIST.
4. THE WATER METER AND ITEMS A,B,C,D,E, & F SHALL BE SUPPLIED AND INSTALLED BY THE BREMERTON PUBLIC WORKS AND UTILITIES DEPARTMENT. ALL OTHER MATERIALS WILL BE SUPPLIED AND INSTALLED BY THE CONTRACTOR, OR HOME OWNER. WHEN THE INSTALLATION IS COMPLETE AND INSPECTED, THE CITY WILL MAINTAIN THE SERVICE UPSTREAM OF THE METER, INSIDE THE RIGHT OF WAY.
5. LOCATE WIRE SHALL BE 12 GA BLUE COATED SOLID COPPER WIRE, STRIPPED AT BOTH ENDS AND TIGHTLY WRAPPED AROUND (GROUNDED TO) THE CORPORATION STOP A MINIMUM OF TWO TIMES OR CRIMPED TO THE LOCATE WIRE ON THE MAIN. THE END IN THE METER BOX SHALL BE LOOPED AND TUCKED INSIDE THE BOX.

	<p>City of Bremerton</p> <hr style="width: 20%; margin: auto;"/> <p>PUBLIC WORKS</p> <hr style="width: 20%; margin: auto;"/> <p>DESIGN/CONSTRUCTION STANDARDS</p>	<p>1" X 3/4" DOMESTIC/IRRIGATION SERVICE CONNECTION</p> <p style="font-size: small;">Alteration of this drawing is prohibited. Any approval of an altered drawing is unauthorized and void.</p>	<p>5001</p> <p style="font-size: small;">Revision Date 11/08/22</p>
---	--	--	--