


NOTES:

1. CONTROL JOINTS SHALL BE SPACED TO CORRESPOND TO THE MARKINGS IN EXISTING SIDEWALKS, OR AS DIRECTED BY THE DIRECTOR.
2. ALL UTILITY POLES, SHALL HAVE A 1-FOOT ISOLATION JOINT OF 3/4" PREMOLDED JOINT FILLER.
3. ALL SIDEWALK EDGES SHALL HAVE 1/2" RADIUS.
4. MINIMUM WIDTH OF SIDEWALK IS 6' (NOT INCLUDING THE WIDTH OF THE CURB OR POLES).
5. THICKENED EDGES ARE REQUIRED FOR SIDEWALKS AT CORNERS, BUT NOT ON TANGENT SECTIONS. ALL CURB RAMPS SHALL HAVE A THICKENED EDGE TO THE DEPTH OF THE ADJACENT CURB, INCLUDING CURB RAMPS BUILT ON TANGENT SECTIONS OF SIDEWALK. WHEN MONOLITHIC CURB AND SIDEWALK IS APPROVED FOR USE, THICKENED EDGES ARE REQUIRED AT ALL LOCATIONS.
6. FOR WHEELCHAIR RAMP USE DETAILS 3111.

	<p>City of Bremerton</p> <hr style="width: 50%; margin: 0 auto;"/> <p>PUBLIC WORKS</p> <hr style="width: 50%; margin: 0 auto;"/> <p>ENGINEERING DIVISION</p>	<p>CONCRETE SIDEWALK CORNER TREATMENT</p> <p style="font-size: small;">Alteration of this drawing is prohibited. Any approval of an altered drawing is unauthorized and void.</p>	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="text-align: center; padding: 5px;">3113</td> </tr> <tr> <td style="text-align: center; padding: 2px 5px;">Revision Date</td> </tr> <tr> <td style="text-align: center; padding: 2px 5px;">3/4/16</td> </tr> </table>	3113	Revision Date	3/4/16
3113						
Revision Date						
3/4/16						