



TYPICAL SECTION

NOTES:

1. FORMS SHALL BE TRUE TO LINE AND GRADE AND SECURELY STAKED.
2. FULL DEPTH EXPANSION JOINTS SHALL BE PLACED ADJACENT TO CATCH BASINS, INLETS AND AT POINTS OF TANGENCY ON STREETS, ALLEY AND DRIVEWAY RETURNS. MAXIMUM SPACING SHALL BE 15 FEET. PRE-MOLDED JOINT FILLER SHALL BE 1/2" WIDE AND CONFORM TO AASHTO DESIGN M213.
3. ALL JOINTS SHALL BE CLEANED AND EDGED.
4. CONCRETE SHALL BE CEMENT CONCRETE, CLASS 3000.
5. STEEL FORMS SHALL BE USED ON TANGENT SECTIONS. WOOD FORMS MAY BE USED ON CURVED SECTIONS.
6. FINISH SHALL BE LIGHT BROOM FINISH.
7. THE FINISHED CURB SHALL BE SPRAYED WITH A TRANSPARENT CURING COMPOUND AND COVERED BY WATERPROOF PAPER OR PLASTIC MEMBRANE IN THE EVENT OF RAIN OR OTHER UNSUITABLE WEATHER. CURING TIME SHALL BE A MINIMUM OF 72 HOURS.
8. ALL CURB AND GUTTER SHALL BE PLACED ON A MINIMUM OF 4" OF COMPACTED CRUSHED SURFACING TOP COURSE (CSTC) OR CRUSHED SURFACING BASE COURSE (CSBC).



CITY OF BREMERTON
ENGINEERING DIVISION
DESIGN / CONSTRUCTION STANDARDS

Alteration of this drawing is prohibited. Any approval of an altered drawing is unauthorized and void.

**CEMENT CONCRETE
CURB AND GUTTER
TYPE A**

DETAIL
3131

Revision Date
09/23/25