



STORM TRENCH DETAIL

N.T.S.

NOTES:

1. MAXIMUM WIDTH OF TRENCH AT TOP OF PIPE *30 INCHES FOR PIPE UP TO AND INCLUDING 12" NOMINAL DIAMETER. *O.D. PLUS 16 INCHES FOR PIPE LARGER THAN 12" NOMINAL DIAMETER.
2. IN PAVED AREAS USE 1" MINUS CRUSHED ROCK BACKFILL UNLESS DIRECTED OTHERWISE BY THE ENGINEER OR AS SHOWN ON THE PLANS. BACKFILL TO BE COMPACTED TO 95%. *FULL DEPTH OF TRENCH WHERE SEWER MAIN CROSSES PERPENDICULAR TO THE TRAVELED LANE OR DRIVEWAY. *TOP FOUR FEET WHERE SEWER MAIN RUNS PARALLEL TO THE TRAVELED LANE, UNLESS EXISTING MATERIAL IS DETERMINED BY THE ENGINEER TO BE SUITABLE FOR BACKFILL 1" CRUSHED ROCK WILL BE USED.
3. TRENCH BACKFILL BELOW TOP FOUR FEET SHALL BE NATIVE MATERIALS OR AS REQUIRED BY THE SPECIFICATIONS.



City of Bremerton

PUBLIC WORKS

DESIGN/CONSTRUCTION STANDARDS

STORMWATER TRENCH DETAIL

Alteration of this drawing is prohibited. Any approval of an altered drawing is unauthorized and void.

4080

Revision Date

10/6/15